



IMPROVING HOSPITALITY
VISIT WATCHMAN - REPAIRING TO 6 STAIRWAYS, ECD ELEV
EVERY TWO HOURS, HEAT, STEAM, HEATS, GAS &
ELECTRIC - NIAGARA AUTO SPRINKLERS, WET SYSTEM
HEADS SPACED 8' X 10' SUPPLIED BY CITY WATER.
DIRECT PRESSURE 90 LBS. BY SHAWNEE STEEL CO.
6' DOWN TO CITY MAIN. BLOG SPRINKLER EXCEPT
2' WARD 5TH FLOOR OF HOSPITAL & 1, 2 & 3 FLOOR
OF NURSES HOME.

18

E. STATE

6 W PIPE

HTEL

AV.

S. BROADWAY

E. EXCHANGE

51